

359 SOUTH PARK DRIVE COLCHESTER, VT 05446

(802) 338-4724 or (800) 660-9997 (VT only)

www.healthvermont.gov

State Health Dept #: Results Report

16-WB-05846

Report Status:

Final

Date Report Released:

07/07/2017

Report To

Town of Londonderry

ATTN OF

Kelly Pajala

Account Name

Town of Londonderry

Address

100 Old School St

Date Received

WSID

07/06/2017

Time Received

09:22

South Londonderry, VT 05155

Approved Date

07/07/2017

Sample Desc.

KIT SW

Collection Date

07/05/2017

Collection Time

13:00

Sampled By

Kelly Pajala

Sampling Location

Pond

Street Address

Memorial Park

Town

Test

South Londonderry

Sample Type

Free Chlorine Residual

Total Chlorine Residual

Chlorinated?

Field Temp.

Field Fluoride

Temp at Receipt

Sampler's Comments

Well fed pond

Enzyme Substrate Quantitation 2000

Date/Time of Analysis 07/07/2017

Test Method SM 9223B-QT

Analyte

E.coli

MPN/100mL

■ The water sample tested was found to contain LESS than 235 E. coli per 100mL. This water is considered SUITABLE FOR SWIMMING. This test does not indicate if the water sample is suitable for drinking. Drinking raw water such as an untreated lake, pond or stream is not advised. **NOTE: It is recommended that testing of recreational water begin within 6 to 24 hours of collection for optimal results but testing must begin within 30 hours of collection.

Units of Measurement and Definitions:

mL = milliliter, > equals greater than, MPN = Most Probable Number, CFU = Colony Forming Unit, TNTC = Too Numerous To Count

The test results included on this report meet all National Environmental Laboratory Accreditation Program requirements unless noted otherwise. Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory. This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1 V.S.A. 315-320).

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By:

Mary efolt

Mary Celotti, Laboratory Director

If you have received this report in error or have questions about this report, please call the laboratory at (802) 338-4724.