

Town of Londonderry

RFP 2018-3EOC

Q&A

Q. Where is the generator to be located?

A. The generator is to be located approximately 5' away from the south (gable) end of the old garage building.

Q. What capacity fuel tank is required?

A. Fuel capacity must be sufficient to allow the generator to run at least 24 hours.

Q. Does the controller need Internet connectivity and what functions must it allow?

A. The controller must have Ethernet connectivity and allow secure on-line access to check the health and status of the generator.

Q. Where should underground lines enter the building?

A. Underground electrical lines should enter the building on the north side of the building to the right of the wooden handicapped ramp.

Q. Will sidewalk cuts be required?

A. Sidewalk cuts should be avoided wherever possible. If sidewalk cuts are necessitated by site conditions, they must be filled and compacted to the appropriate level to allow ease of repair.